



**NOTES:**

1. DETAIL SHOWS HENRY® **PUMADECQ™** SYSTEM WATERPROOFING ASSEMBLY WITH AN UNREINFORCED FIELD MEMBRANE. SUBSTRATE SHOWN IS FOR REFERENCE ONLY. REFER TO PRODUCT SPECIFIC TECHNICAL DATA SHEET FOR AUTHORIZED SUBSTRATES.
2. SURFACE PROFILES MUST MEET ICRI CSP 3-4. IF CSP 5, REFER TO REINFORCED **PUMADECQ™** SYSTEM DETAILS.
3. REMOVE EXCESS PRIMER FROM GAP PRIOR TO APPLYING **PUMADECQ™ FLEX 30SL**.
4. PREPARE AND PRIME VERTICAL SUBSTRATES A MINIMUM 2" BEYOND **PUMADECQ™** SYSTEM APPLICATION IN ACCORDANCE WITH HENRY® **PUMADECQ™** SYSTEM SUBSTRATE PREPARATION GUIDELINES TECH-TALK BULLETIN
5. DO NOT INSTALL **PUMADECQ™** SYSTEM BEYOND PRIMED SURFACES.
6. BACK COAT FLEECE ON VERTICAL SURFACES WITH **PUMADECQ™** RESIN.
7. HENRY® OFFERS PAVERS, RIGID INSULATION, AND/OR PREFABRICATED DRAINAGE COMPOSITES AS A SINGLE SOURCE WARRANTY OPTION PER PROJECT SPECIFIC REQUIREMENTS (NOT SHOWN FOR CLARITY). CONTACT HENRY® FOR SYSTEM CONFIGURATIONS AND WARRANTY OPTIONS.
8. REFER TO **PUMADECQ™** SYSTEM GUIDE SPECIFICATION FOR RECOMMENDED INSTALLATION PROCEDURES.

**Henry**®

999 N. Pacific Coast Highway, Suite 800  
 El Segundo, CA 90245  
 800-486-1278 • www.henry.com

MANUFACTURER GUIDE DETAILS ARE FOR REFERENCE ONLY. HENRY® DOES NOT ASSUME RESPONSIBILITY FOR ERRORS OR DEVIATIONS IN DESIGN OR ENGINEERING. PROJECT SPECIFIC VERIFICATION IS RECOMMENDED PRIOR TO INSTALLATION.

**PUMADECQ™ SYSTEM - WATERPROOFING ASSEMBLY**

**NON-MOVING JOINT**

**UNREINFORCED FIELD MEMBRANE NON-MOVING JOINT AT UPTURN WITH TOP OR WEAR COAT**

SCALE: N.T.S.

04-26-2019

**PUMADECQ-S10**