



Notes

1. This detail allows the opening to be completed before the stack is in place. The metal sleeve and the clearance necessary will depend on the temperature of the material handled by the stack.
2. Cant strips are not required when the cap flashing or all plies are thermofused.
3. Vertical wood member may be replaced by an upgraded assembly as shown in detail MB-13E97.

modifiedPLUS Roofing Systems

STACK FLASHING

CONVENTIONAL ROOFING ASSEMBLY

Scale: N.T.S.

Plot: 1:5

Issued: 05-14-97

Revision: 04

MB-10E97



Henry Company
 2911 Slauson Avenue, Huntington Park CA 90255
 (800) 486-1278 techservices@henry.com
<http://www.henry.com>